

Notified body No. 1397

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

## 1397-CPR-0541

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011, this certificate applies to the construction product

**self-supporting double skin metal faced insulating panels**

Parameters (type): **panels with polyisocyanurate rigid foam (PIR) core**  
(see Annex 1)

Intended use: **external and internal walls (including partitions)**

Placed on the market under the name of

**UAB "BEWI LITHUANIA",**

**S. Lozoraičio str. 15A, LT-53229 Garliava, Kaunas region**

Produced in the manufacturing plant

**UAB "BEWI LITHUANIA",**

**J. Basanavičiaus str. 122, LT-28214 Utena**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 14509:2013**

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to **ensure the constancy of performance of the construction product**

This certificate was first issued on **2016-07-01** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body.

Information about validity of this certificate is published at [www.spsc.lt](http://www.spsc.lt)

Director



Valdemaras Gauronskis

Vilnius, 2024-07-16



Notified body No. 1397

ANNEX 1 TO  
CERTIFICATE OF CONSTANCY OF PERFORMANCE

1397-CPR-0541

Issued on 2024-07-16

Panel type	Panel intended use	Panel thickness, mm	Panel width, mm	Reaction to fire class
PIR 50-80 NF 1000WP	external and internal walls (including partitions), ceilings	50-80	1000	B-s2, d0
PIR 100-200 NF 1000WP	external and internal walls (including partitions), ceilings	100-200	1000	B-s1, d0
PIR 50-80 NF 1200WP	external and internal walls (including partitions), ceilings	50-80	1200	B-s2, d0
PIR 100-200 NF 1200WP	external and internal walls (including partitions), ceilings	100-200	1200	B-s1, d0

Director



Valdemaras Gauronskis